



TYPICAL SECTION

- ALTERNATE SIZE REDWOOD BLOCKING MAY BE USED, SUBJECT TO APPROVAL BY THE ENGINEER. MINIMUM CLEARANCE SHALL BE MAINTAINED.
- TWO BLOCK ANGLES COULD VARY TO MAINTAIN REQUIRED CLEARANCES AND PROPER INSTALLATION.
- STEEL CASING PIPE TO BE (3/8" WALL THICKNESS) MINIMUM.
- ALL STEEL CASING SHALL BE WELDED CONTINUOUSLY AT ALL JOINTS
- ALL STEEL SHALL BE STRUCTURAL GRADE PER A.S.T.M. A283 OR A.S.T.M. A36 STEEL.
- ALL D.I.P PIPE SHALL HAVE RESTRAINED OR FLANGED JOINTS AS CALLED FOR ON PLANS

APPROVED: _____
CITY ENGINEER DATE